

11. 薬品使用状況

(1) 次亜塩素酸ナトリウム

浄水場 区分 年度・月	※1) ちば野菊の里浄水場				※2) 栗山浄水場				柏井浄水場 東側			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L
R4(2022)	21,847,390	207,582	24,910	1.14	51,808,570	1,224,176	146,901	2.84	33,529,280	2,141,600	256,992	7.66
R5(2023)	25,623,220	231,481	27,778	1.08	48,308,830	1,058,162	126,979	2.63	30,788,930	2,304,840	276,581	8.98
4月	1,839,940	13,690	1,643	0.89	3,942,960	82,655	9,919	2.52	2,707,680	220,000	26,400	9.75
5	1,902,870	14,462	1,735	0.91	4,095,360	97,737	11,728	2.86	2,828,230	230,430	27,652	9.78
6	1,836,410	15,811	1,897	1.03	3,881,920	115,617	13,874	3.57	2,540,400	189,590	22,751	8.96
7	1,900,650	20,525	2,463	1.30	4,220,100	155,261	18,631	4.41	2,261,000	242,950	29,154	12.89
8	1,892,810	20,973	2,517	1.33	4,066,720	129,749	15,570	3.83	2,086,340	271,280	32,554	15.60
9	1,834,860	18,935	2,272	1.24	3,980,140	111,553	13,386	3.36	2,153,740	207,940	24,953	11.59
10	1,896,920	15,372	1,845	0.97	4,431,870	91,652	10,998	2.48	2,510,060	172,810	20,737	8.26
11	1,810,910	14,095	1,691	0.93	4,570,020	82,249	9,870	2.16	2,553,950	155,090	18,611	7.29
12	1,806,830	12,057	1,447	0.80	4,282,070	65,388	7,847	1.83	2,723,110	153,920	18,470	6.78
1	1,641,380	12,229	1,467	0.89	4,068,430	62,550	7,506	1.84	2,942,570	156,920	18,830	6.40
2	1,733,190	15,512	1,861	1.07	2,819,030	56,944	6,833	2.42	2,791,650	152,290	18,275	6.55
3	5,526,450	57,820	6,938	1.26	3,948,210	6,807	817	0.21	2,690,200	151,620	18,194	6.76

(※1) R5年度3月2期施設浄水処理開始

(※2) R5年度3月浄水処理停止、以降追塩

浄水場 区分 年度・月	柏井浄水場 西側				木下取水場 (北総系)				木下取水場 (柏井系)			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L
R4(2022)	92,178,420	1,879,680	225,562	2.45	29,583,010	324,702	38,964	1.32	61,912,010	668,728	80,247	1.30
R5(2023)	93,081,210	1,854,740	222,569	2.39	28,866,440	337,482	40,498	1.40	60,884,490	718,018	86,162	1.42
4月	7,830,210	117,890	14,147	1.81	3,706,600	42,748	5,130	1.38	7,830,210	90,437	10,852	1.39
5	7,820,400	134,450	16,134	2.06	3,802,520	54,469	6,536	1.72	7,824,490	112,646	13,518	1.73
6	8,229,250	143,290	17,195	2.09	3,698,030	50,328	6,039	1.63	8,231,140	112,232	13,468	1.64
7	9,046,160	174,620	20,954	2.32	3,842,100	57,876	6,945	1.81	9,049,950	136,444	16,373	1.81
8	8,445,620	192,830	23,140	2.74	3,876,230	39,478	4,737	1.22	8,448,120	86,762	10,411	1.23
9	8,070,190	182,340	21,881	2.71	3,654,820	36,550	4,386	1.20	8,073,150	80,742	9,689	1.20
10	6,419,860	116,810	14,017	2.18	3,777,310	40,055	4,807	1.27	6,422,760	67,979	8,157	1.27
11	6,125,420	122,310	14,677	2.40	967,140	7,136	856	0.89	1,538,880	11,174	1,341	0.87
12	6,999,730	135,910	16,309	2.33	0	0	0	0.00	0	0	0	0.00
1	7,098,160	164,460	19,735	2.78	875,030	4,751	570	0.65	1,644,620	8,618	1,034	0.63
2	8,217,590	182,460	21,895	2.66	415,660	1,562	187	0.45	1,211,560	4,843	581	0.48
3	8,778,620	187,370	22,484	2.56	251,000	2,529	303	1.21	609,610	6,141	737	1.21

浄水場 区分 年度・月	北総浄水場				福増浄水場				北船橋給水場			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L
R4(2022)	43,100,170	1,186,616	142,394	3.30	19,687,430	528,645	63,437	3.22	88,821,500	18,587	2,230	0.03
R5(2023)	44,740,920	1,157,081	138,850	3.10	19,307,040	598,887	71,866	3.72	88,315,200	21,370	2,564	0.03
4月	3,706,600	83,929	10,071	2.72	1,795,810	49,587	5,950	3.31	7,634,920	2,488	299	0.04
5	3,802,520	96,662	11,599	3.05	1,670,870	51,176	6,141	3.68	7,884,360	2,488	299	0.04
6	3,698,030	85,580	10,270	2.78	1,604,660	47,177	5,661	3.53	7,846,310	213	26	0.00
7	3,842,100	101,048	12,126	3.16	1,792,610	60,827	7,299	4.07	7,819,160	2,798	336	0.04
8	3,876,230	117,462	14,095	3.64	1,559,100	63,919	7,670	4.92	7,200,930	3,280	394	0.05
9	3,654,820	105,527	12,663	3.46	1,374,400	55,905	6,709	4.88	6,922,900	1,428	171	0.02
10	3,777,310	89,210	10,705	2.83	1,583,030	53,926	6,471	4.09	7,020,820	1,097	132	0.02
11	3,577,030	89,007	10,681	2.99	1,503,340	47,912	5,749	3.82	6,768,830	2,564	308	0.05
12	3,812,980	95,290	11,435	3.00	1,580,120	39,701	4,764	3.02	7,069,720	1,501	180	0.03
1	3,846,740	103,327	12,399	3.22	1,663,460	36,172	4,341	2.61	7,222,410	786	94	0.01
2	3,272,510	87,485	10,498	3.21	1,532,950	44,036	5,284	3.45	7,292,990	1,164	140	0.02
3	3,874,050	102,554	12,306	3.18	1,646,690	48,549	5,826	3.54	7,631,850	1,563	188	0.02

浄水場 区分 年度・月	北習志野分場				松戸給水場				沼南給水場			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L	㎥	kg	kg	mg/L
R4(2022)	0	0	0	0.00	15,111,260	16,956	2,035	0.13	57,733,630	49,633	5,956	0.10
R5(2023)	0	0	0	0.00	16,635,860	15,539	1,865	0.11	67,796,770	68,575	8,229	0.12
4月	0	0	0	0.00	1,280,680	793	95	0.07	5,080,860	3,466	416	0.08
5	0	0	0	0.00	1,501,360	1,378	165	0.11	6,601,980	6,235	748	0.11
6	0	0	0	0.00	854,820	427	51	0.06	6,429,090	7,671	921	0.14
7	0	0	0	0.00	1,580,100	2,069	248	0.16	6,975,790	11,574	1,389	0.20
8	0	0	0	0.00	1,566,280	2,325	279	0.18	6,981,040	12,316	1,478	0.21
9	0	0	0	0.00	1,480,620	2,185	262	0.18	6,709,740	12,623	1,515	0.23
10	0	0	0	0.00	1,462,960	1,200	144	0.10	8,166,280	5,610	673	0.08
11	0	0	0	0.00	1,190,460	738	89	0.07	7,000,370	4,029	483	0.07
12	0	0	0	0.00	1,517,210	1,263	152	0.10	3,171,160	877	105	0.03
1	0	0	0	0.00	1,502,150	1,201	144	0.10	1,508,460	337	40	0.03
2	0	0	0	0.00	1,373,330	1,015	122	0.09	3,162,790	915	110	0.03
3	0	0	0	0.00	1,325,890	945	113	0.09	6,009,210	2,922	351	0.06

浄水場 区分 年度・月	船橋給水場				姉崎分場				市原分場			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	6,123,700	4,252	510	0.08	19,116,360	21,830	2,620	0.14	1,860	1	0	0.06
R5(2023)	11,633,020	4,880	586	0.05	20,402,400	27,337	3,280	0.16	0	0	0	0
4月	181,680	30	4	0.02	1,467,130	2,015	242	0.16	0	0	0	0.00
5	348,220	87	10	0.03	1,735,770	2,007	241	0.14	0	0	0	0.00
6	127,760	26	3	0.02	1,685,130	2,317	278	0.16	0	0	0	0.00
7	659,850	221	27	0.04	1,737,850	2,526	303	0.17	0	0	0	0.00
8	1,141,460	455	55	0.05	1,890,770	3,614	434	0.23	0	0	0	0.00
9	1,123,400	381	46	0.04	1,829,870	3,092	371	0.20	0	0	0	0.00
10	1,322,600	579	69	0.05	1,891,780	2,854	342	0.18	0	0	0	0.00
11	1,487,690	957	115	0.08	1,829,250	1,625	195	0.11	0	0	0	0.00
12	1,854,680	893	107	0.06	1,887,190	1,643	197	0.10	0	0	0	0.00
1	1,861,090	955	115	0.06	1,509,970	1,954	234	0.16	0	0	0	0.00
2	1,094,460	236	28	0.03	1,415,420	1,908	229	0.16	0	0	0	0.00
3	430,130	60	7	0.02	1,522,270	1,782	214	0.14	0	0	0	0.00

浄水場 区分 年度・月	菅田給水場				千葉分場				大宮分場			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(12%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	25,266,550	20,371	2,445	0.10	6,720	202	24	3.61	10,530	242	29	2.76
R5(2023)	24,541,990	29,786	3,574	0.15	0	0	0	0.00	0	0	0	0.00
4月	2,011,580	2,260	271	0.13	0	0	0	0.00	0	0	0	0.00
5	2,084,210	2,281	274	0.13	0	0	0	0.00	0	0	0	0.00
6	2,043,360	2,248	270	0.13	0	0	0	0.00	0	0	0	0.00
7	2,150,930	3,670	440	0.20	0	0	0	0.00	0	0	0	0.00
8	2,111,590	4,281	514	0.24	0	0	0	0.00	0	0	0	0.00
9	2,038,460	4,257	511	0.25	0	0	0	0.00	0	0	0	0.00
10	2,107,600	2,995	359	0.17	0	0	0	0.00	0	0	0	0.00
11	2,033,010	1,257	151	0.07	0	0	0	0.00	0	0	0	0.00
12	2,100,360	1,715	206	0.10	0	0	0	0.00	0	0	0	0.00
1	2,082,740	1,293	155	0.07	0	0	0	0.00	0	0	0	0.00
2	1,913,970	1,815	218	0.11	0	0	0	0.00	0	0	0	0.00
3	1,864,180	1,714	206	0.11	0	0	0	0.00	0	0	0	0.00

浄水場 区分 年度・月	成田給水場				幕張給水場(生成次亜)				妙典給水場(生成次亜)			
	処理量	注入量(12%)	100%換算	注入率	処理量	注入量(1%)	100%換算	注入率	処理量	注入量(1%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	3,299,570	1,039	125	0.04	21,864,500	313,465	3,135	0.14	25,466,097	375,173	3,752	0.15
R5(2023)	3,687,959	328	39	0.01	21,618,180	534,195	5,342	0.25	31,106,410	407,196	4,072	0.13
4月	0	0	0	0.00	1,786,830	42,416	424	0.24	2,732,820	15,812	158	0.06
5	0	0	0	0.00	1,821,960	54,139	541	0.30	2,998,270	19,526	195	0.07
6	307,446	25	3	0.01	1,819,830	60,714	607	0.33	3,157,220	57,925	579	0.18
7	388,890	18	2	0.01	1,939,740	72,884	729	0.38	3,440,980	85,186	852	0.25
8	326,640	9	1	0.00	1,885,240	70,494	705	0.37	3,360,900	78,579	786	0.23
9	385,870	11	1	0.00	1,800,240	48,186	482	0.27	3,181,660	68,294	683	0.21
10	125,820	9	1	0.01	1,836,180	39,192	392	0.21	3,215,580	45,390	454	0.14
11	399,323	35	4	0.01	1,721,000	26,907	269	0.16	647,520	2,011	20	0.03
12	442,190	111	13	0.03	1,777,300	30,144	301	0.17	2,241,080	9,739	97	0.04
1	438,730	26	3	0.01	1,807,440	28,928	289	0.16	1,505,050	5,701	57	0.04
2	427,770	46	6	0.01	1,634,900	31,820	318	0.19	1,840,790	7,942	79	0.04
3	445,280	38	5	0.01	1,787,520	28,371	284	0.16	2,784,540	11,091	111	0.04

浄水場 区分 年度・月	計		
	処理量	注入量(100%換算)	注入率
	m ³	kg	mg/L
R4(2022)	616,468,557	1,002,267	1.63
R5(2023)	637,336,869	1,020,835	1.60
4月	55,536,510	86,021	1.55
5	58,723,390	97,518	1.66
6	57,990,806	93,893	1.62
7	62,647,960	118,272	1.89
8	60,716,020	115,339	1.90
9	58,268,880	99,981	1.72
10	57,968,740	80,305	1.39
11	45,724,143	65,111	1.42
12	43,265,730	61,631	1.42
1	43,218,430	67,016	1.55
2	42,150,560	66,665	1.58
3	51,125,700	69,084	1.35

(2) 苛性ソーダ

浄水場 区分 年度・月	※1) ちば野菊の里浄水場				※2) 栗山浄水場				柏井浄水場 東側			
	処理量	注入量(45%)	100%換算	注入率	処理量	注入量(45%)	100%換算	注入率	処理量	注入量(45%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	21,847,390	229,600	103,320	4.73	51,808,570	526,754	237,039	4.58	33,529,280	390,420	175,689	5.24
R5(2023)	25,623,220	273,329	122,998	4.80	44,412,290	458,356	206,260	4.64	30,788,930	266,790	120,056	3.90
4月	1,839,940	14,168	6,376	3.47	3,942,960	34,774	15,648	3.97	2,707,680	22,010	9,905	3.66
5	1,902,870	18,690	8,411	4.42	4,095,360	36,641	16,488	4.03	2,828,230	27,740	12,483	4.41
6	1,836,410	22,392	10,076	5.49	3,881,920	35,206	15,843	4.08	2,540,400	14,800	6,660	2.62
7	1,900,650	28,638	12,887	6.78	4,220,100	46,050	20,723	4.91	2,261,000	14,870	6,692	2.96
8	1,892,810	30,195	13,588	7.18	4,066,720	54,606	24,573	6.04	2,086,340	15,550	6,998	3.35
9	1,834,860	26,971	12,137	6.61	3,980,140	53,002	23,851	5.99	2,153,740	14,920	6,714	3.12
10	1,896,920	21,776	9,799	5.17	4,431,870	57,428	25,843	5.83	2,510,060	16,900	7,605	3.03
11	1,810,910	16,112	7,250	4.00	4,570,020	53,101	23,895	5.23	2,553,950	18,740	8,433	3.30
12	1,806,830	14,641	6,588	3.65	4,282,070	22,486	10,119	2.36	2,723,110	24,050	10,823	3.97
1	1,641,380	13,594	6,117	3.73	4,068,430	30,769	13,846	3.40	2,942,570	29,270	13,172	4.48
2	1,733,190	17,184	7,733	4.46	2,819,030	33,133	14,910	5.29	2,791,650	38,940	17,523	6.28
3	5,526,450	48,968	22,036	3.99	53,670	1,160	522	9.73	2,690,200	29,000	13,050	4.85

(※1) R5年度3月2期施設浄水処理開始

(※2) R5年度3月浄水処理停止

浄水場 区分 年度・月	柏井浄水場 西側				※3) 北総浄水場				福増浄水場			
	処理量	注入量(45%)	100%換算	注入率	処理量	注入量(45%)	100%換算	注入率	処理量	注入量(45%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	92,178,420	988,120	444,654	4.82	43,096,410	294,520	132,534	3.08	19,687,430	416,530	187,439	9.52
R5(2023)	93,081,210	1,019,230	458,654	4.93	44,722,635	408,823	163,719	4.11	19,307,040	501,295	225,583	11.68
4月	7,830,210	75,540	33,993	4.34	3,706,600	20,880	9,396	2.53	1,795,810	47,687	21,459	11.95
5	7,820,400	74,280	33,426	4.27	3,802,520	20,970	9,437	2.48	1,670,870	44,448	20,002	11.97
6	8,229,250	89,440	40,248	4.89	3,698,030	20,090	9,041	2.44	1,604,660	57,501	25,875	16.13
7	9,046,160	91,760	41,292	4.56	3,842,100	29,490	13,271	3.45	1,792,610	76,359	34,362	19.17
8	8,445,620	103,170	46,427	5.50	3,876,230	43,120	19,404	5.01	1,559,100	58,046	26,121	16.75
9	8,070,190	82,340	37,053	4.59	3,653,330	39,540	17,793	4.87	1,374,400	48,224	21,701	15.79
10	6,419,860	67,600	30,420	4.74	3,776,240	29,010	13,055	3.46	1,583,030	48,240	21,708	13.71
11	6,125,420	72,140	32,463	5.30	3,568,560	28,810	12,965	3.63	1,503,340	26,430	11,894	7.91
12	6,999,730	87,970	39,587	5.66	3,812,430	35,370	15,917	4.17	1,580,120	20,206	9,093	5.75
1	7,098,160	76,960	34,632	4.88	3,846,210	30,800	13,860	3.60	1,663,460	18,984	8,543	5.14
2	8,217,590	90,310	40,640	4.95	3,266,335	36,405	10,995	3.37	1,532,950	23,650	10,643	6.94
3	8,778,620	107,720	48,474	5.52	3,874,050	74,338	18,585	4.80	1,646,690	31,520	14,184	8.61

(※3) R5年度2月から苛性ソーダ25%を使用

浄水場 区分 年度・月	沼南給水場				姉崎分場				計		
	処理量	注入量(20%)	100%換算	注入率	処理量	注入量(25%)	100%換算	注入率	処理量	注入量(100%換算)	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	mg/L
R4(2022)	0	0	0	0.00	0	0	0	0.00	262,147,500	1,280,676	4.89
R5(2023)	0	0	0	0.00	0	0	0	0.00	257,935,325	1,297,267	5.03
4月	0	0	0	0.00	0	0	0	0.00	21,823,200	96,777	4.43
5	0	0	0	0.00	0	0	0	0.00	22,120,250	100,246	4.53
6	0	0	0	0.00	0	0	0	0.00	21,790,670	107,743	4.94
7	0	0	0	0.00	0	0	0	0.00	23,062,620	129,225	5.60
8	0	0	0	0.00	0	0	0	0.00	21,926,820	137,109	6.25
9	0	0	0	0.00	0	0	0	0.00	21,066,660	119,249	5.66
10	0	0	0	0.00	0	0	0	0.00	20,617,980	108,429	5.26
11	0	0	0	0.00	0	0	0	0.00	20,132,200	96,900	4.81
12	0	0	0	0.00	0	0	0	0.00	21,204,290	92,125	4.34
1	0	0	0	0.00	0	0	0	0.00	21,260,210	90,170	4.24
2	0	0	0	0.00	0	0	0	0.00	20,360,745	102,443	5.03
3	0	0	0	0.00	0	0	0	0.00	22,569,680	116,850	5.18

(3) 硫酸

浄水場 区分 年度・月	※1) ちば野菊の里浄水場				※2) 栗山浄水場				柏井浄水場東側			
	処理量	注入量 (75%)	100%換算	注入率	処理量	注入量 (75%)	100%換算	注入率	処理量	注入量 (95%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	15,979,350	97,065	72,799	4.56	37,435,190	285,140	213,855	5.71	33,529,280	678,300	644,385	19.22
R5(2023)	21,780,040	132,691	99,518	4.57	43,341,130	380,649	285,487	6.59	30,649,940	485,330	461,064	15.04
4月	1,614,990	6,529	4,897	3.03	3,942,960	29,666	22,250	5.64	2,707,680	45,360	43,092	15.91
5	986,990	2,799	2,099	2.13	3,497,120	17,785	13,339	3.81	2,828,230	35,080	33,326	11.78
6	109,980	304	228	2.07	3,409,000	10,279	7,709	2.26	2,540,400	21,780	20,691	8.14
7	1,679,430	12,699	9,524	5.67	4,220,100	45,954	34,466	8.17	2,261,000	19,050	18,098	8.00
8	1,758,615	15,180	11,385	6.47	4,066,720	49,110	36,833	9.06	2,086,340	18,610	17,680	8.47
9	1,834,860	12,725	9,544	5.20	3,980,140	50,090	37,568	9.44	2,014,750	15,730	14,944	7.42
10	1,896,920	12,050	9,038	4.76	4,431,870	61,619	46,214	10.43	2,510,060	33,290	31,626	12.60
11	1,810,910	8,389	6,292	3.47	4,570,020	49,501	37,126	8.12	2,553,950	47,760	45,372	17.77
12	1,806,830	10,031	7,523	4.16	4,282,070	14,301	10,726	2.50	2,723,110	69,040	65,588	24.09
1	1,641,380	7,925	5,944	3.62	4,068,430	22,996	17,247	4.24	2,942,570	68,290	64,876	22.05
2	1,733,190	8,040	6,030	3.48	2,819,030	28,670	21,503	7.63	2,791,650	58,160	55,252	19.79
3	4,905,945	36,020	27,015	5.51	53,670	678	509	9.47	2,690,200	53,180	50,521	18.78

(※1) R5年度3月2期施設浄水処理開始

(※2) R5年度3月浄水処理停止

浄水場 区分 年度・月	柏井浄水場西側				北総浄水場				福増浄水場			
	処理量	注入量 (45%)	100%換算	注入率	処理量	注入量 (45%)	100%換算	注入率	処理量	注入量 (75%)	100%換算	注入率
	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L	m ³	kg	kg	mg/L
R4(2022)	92,178,420	698,030	314,114	3.41	40,315,092	596,996	268,648	6.66	19,687,430	527,003	395,252	20.08
R5(2023)	87,517,950	747,230	336,254	3.84	42,295,811	574,118	258,353	6.11	19,307,040	653,224	489,918	25.38
4月	7,830,210	78,880	35,496	4.53	3,706,600	50,632	22,784	6.15	1,795,810	59,069	44,302	24.67
5	6,446,080	24,010	10,805	1.68	3,592,060	25,628	11,533	3.21	1,670,870	41,915	31,436	18.81
6	6,455,280	20,980	9,441	1.46	1,847,252	12,154	5,469	2.96	1,604,660	36,618	27,464	17.11
7	9,046,160	68,390	30,776	3.40	3,694,570	57,190	25,736	6.97	1,792,610	83,845	62,884	35.08
8	7,574,670	59,740	26,883	3.55	3,876,230	72,862	32,788	8.46	1,559,100	73,488	55,116	35.35
9	6,526,170	31,020	13,959	2.14	3,571,206	61,248	27,562	7.72	1,374,400	49,545	37,159	27.04
10	6,419,860	48,260	21,717	3.38	3,773,290	50,258	22,616	5.99	1,583,030	61,803	46,352	29.28
11	6,125,420	64,690	29,111	4.75	3,575,460	45,320	20,394	5.70	1,503,340	36,044	27,033	17.98
12	6,999,730	104,010	46,805	6.69	3,812,810	61,416	27,637	7.25	1,580,120	46,624	34,968	22.13
1	7,098,160	75,710	34,070	4.80	3,846,430	50,096	22,543	5.86	1,663,460	61,175	45,881	27.58
2	8,217,590	72,300	32,535	3.96	3,267,593	27,068	12,181	3.73	1,532,950	61,541	46,156	30.11
3	8,778,620	99,240	44,658	5.09	3,732,310	60,246	27,111	7.26	1,646,690	41,557	31,168	18.93

浄水場 区分 年度・月	計		
	処理量	注入量 (100%換算)	注入率
	m ³	kg	mg/L
R4(2022)	239,124,762	1,909,053	7.98
R5(2023)	244,891,911	1,930,593	7.88
4月	21,598,250	172,820	8.00
5	19,021,350	102,537	5.39
6	15,966,572	71,002	4.45
7	22,693,870	181,482	8.00
8	20,921,675	180,684	8.64
9	19,301,526	140,734	7.29
10	20,615,030	177,563	8.61
11	20,139,100	165,327	8.21
12	21,204,670	193,247	9.11
1	21,260,430	190,560	8.96
2	20,362,003	173,656	8.53
3	21,807,435	180,981	8.30

(4) 粉末活性炭

浄水場 区分 年度・月	(**1) ちば野菊の里浄水場			(**2) 栗山浄水場			柏井浄水場東側			柏井浄水場西側		
	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率
	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L
R4(2022)	9,850	100	10.15	51,808,570	547,552	10.57	2,960,370	1,623	0.55	92,211,040	1,892,814	20.53
R5(2023)	0	0	0.00	44,412,290	485,127	10.92	1,770,940	299	0.17	93,117,630	2,158,872	23.18
4月	0	0	0.00	3,942,960	48,720	12.36	183,850	12	0.07	7,830,210	225,411	28.79
5	0	0	0.00	4,095,360	42,320	10.33	191,700	13	0.07	7,824,490	234,778	30.01
6	0	0	0.00	3,881,920	52,820	13.61	155,480	16	0.10	8,231,140	220,232	26.76
7	0	0	0.00	4,220,100	66,530	15.77	200,270	191	0.95	9,049,950	247,261	27.32
8	0	0	0.00	4,066,720	89,347	21.97	0	0	0.00	8,448,120	285,424	33.79
9	0	0	0.00	3,980,140	47,000	11.81	70,990	5	0.07	8,073,150	199,073	24.66
10	0	0	0.00	4,431,870	21,420	4.83	163,220	8	0.05	6,422,760	124,250	19.35
11	0	0	0.00	4,570,020	23,800	5.21	85,250	6	0.07	6,128,910	93,573	15.27
12	0	0	0.00	4,282,070	27,900	6.52	262,920	15	0.06	7,004,160	97,899	13.98
1	0	0	0.00	4,068,430	34,150	8.39	97,810	10	0.10	7,100,910	130,866	18.43
2	0	0	0.00	2,819,030	30,670	10.88	185,580	11	0.06	8,221,490	146,509	17.82
3	0	0	0.00	53,670	450	8.38	173,870	12	0.07	8,782,340	153,596	17.49

(※1) R5年度3月2期施設浄水処理開始

(※2) R5年度3月浄水処理停止

浄水場 区分 年度・月	北総浄水場			福増浄水場			計		
	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率
	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L
R4(2022)	43,100,170	909,142	21.09	19,687,430	123,588	6.28	209,777,430	3,474,819	16.56
R5(2023)	44,740,920	1,027,329	22.96	19,307,040	99,235	5.14	203,348,820	3,770,862	18.54
4月	3,706,600	106,640	28.77	1,795,810	10,631	5.92	17,459,430	391,414	22.42
5	3,802,520	114,867	30.21	1,670,870	9,610	5.75	17,584,940	401,588	22.84
6	3,698,030	100,684	27.23	1,604,660	11,500	7.17	17,571,230	385,252	21.93
7	3,842,100	104,649	27.24	1,792,610	19,900	11.10	19,105,030	438,531	22.95
8	3,876,230	132,056	34.07	1,559,100	16,138	10.35	17,950,170	522,965	29.13
9	3,654,820	89,918	24.60	1,374,400	10,127	7.37	17,153,500	346,123	20.18
10	3,777,310	73,199	19.38	1,583,030	8,065	5.09	16,378,190	226,942	13.86
11	3,577,030	54,574	15.26	1,503,340	6,083	4.05	15,864,550	178,036	11.22
12	3,812,980	53,413	14.01	1,580,120	945	0.60	16,942,250	180,172	10.63
1	3,846,740	70,805	18.41	1,663,460	6,035	3.63	16,777,350	241,866	14.42
2	3,272,510	58,589	17.90	1,532,950	0	0.00	16,031,560	235,779	14.71
3	3,874,050	67,935	17.54	1,646,690	201	0.12	14,530,620	222,194	15.29

(5) 粒状活性炭

浄水場 年度・月	(**1) ちば野菊の里 使用量		
	柏井使用量	福増使用量	
	m ³	kg	m ³
R4(2022)	113	212,680	306
R5(2023)	114	154,110	303
4月	0	20,860	0
5	0	10,300	0
6	0	13,380	0
7	0	10,150	0
8	0	12,760	0
9	114	11,950	0
10	0	5,250	0
11	0	6,080	75
12	0	19,530	228
1	0	10,680	0
2	0	3,990	0
3	0	29,180	0

(※1) R5年度3月2期施設浄水処理開始

(6) ポリ塩化アルミニウム

浄水場 区分 年度・月	〔※1〕ちば野菊の里浄水場			〔※2〕栗山浄水場			柏井浄水場東側			柏井浄水場西側		
	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率
	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L
R4(2022)	21,847,390	826,804	37.84	51,808,570	2,009,056	38.78	33,529,280	2,980,920	88.90	92,178,420	3,994,570	43.34
R5(2023)	25,623,220	948,132	37.00	44,412,290	1,557,866	35.08	30,788,930	2,814,710	91.42	93,081,210	4,511,740	48.47
4月	1,839,940	65,583	35.64	3,942,960	130,108	33.00	2,707,680	232,710	85.94	7,830,210	329,100	42.03
5	1,902,870	63,384	33.31	4,095,360	129,930	31.73	2,828,230	246,030	86.99	7,820,400	317,720	40.63
6	1,836,410	64,211	34.97	3,881,920	136,554	35.18	2,540,400	193,300	76.09	8,229,250	370,570	45.03
7	1,900,650	78,045	41.06	4,220,100	161,931	38.37	2,261,000	235,830	104.30	9,046,160	531,160	58.72
8	1,892,810	70,564	37.28	4,066,720	187,965	46.22	2,086,340	277,820	133.16	8,445,620	331,330	39.23
9	1,834,860	72,054	39.27	3,980,140	149,837	37.65	2,153,740	231,400	107.44	8,070,190	404,560	50.13
10	1,896,920	77,860	41.05	4,431,870	138,673	31.29	2,510,060	220,190	87.72	6,419,860	360,990	56.23
11	1,810,910	64,175	35.44	4,570,020	144,890	31.70	2,553,950	205,810	80.58	6,125,420	217,190	35.46
12	1,806,830	67,546	37.38	4,282,070	137,080	32.01	2,723,110	193,880	71.20	6,999,730	297,960	42.57
1	1,641,380	60,098	36.61	4,068,430	143,339	35.23	2,942,570	276,150	93.85	7,098,160	378,550	53.33
2	1,733,190	64,502	37.22	2,819,030	95,964	34.04	2,791,650	267,090	95.67	8,217,590	483,810	58.87
3	5,526,450	200,110	36.21	53,670	1,595	29.72	2,690,200	234,500	87.17	8,778,620	488,800	55.68

(※1) R5年度3月2期施設浄水処理開始

(※2) R5年度3月浄水処理停止

浄水場 区分 年度・月	北総浄水場			〔※3〕福増浄水場			計		
	処理量	注入量	注入率	処理量	注入量	注入率	処理量	注入量	注入率
	m ³	kg	mg/L	m ³	kg	mg/L	m ³	kg	mg/L
R4(2022)	43,100,170	1,997,780	46.35	19,687,430	1,267,938	64.40	262,151,260	13,077,068	49.88
R5(2023)	44,740,920	2,179,821	48.72	19,307,040	1,226,654	63.53	257,953,610	13,238,923	51.32
4月	3,706,600	161,270	43.51	1,795,810	97,111	54.08	21,823,200	1,015,882	46.55
5	3,802,520	162,750	42.80	1,670,870	103,467	61.92	22,120,250	1,023,281	46.26
6	3,698,030	164,220	44.41	1,604,660	100,543	62.66	21,790,670	1,029,398	47.24
7	3,842,100	207,570	54.03	1,792,610	104,343	58.21	23,062,620	1,318,879	57.19
8	3,876,230	234,450	60.48	1,559,100	150,121	96.29	21,926,820	1,252,250	57.11
9	3,654,820	187,240	51.23	1,374,400	123,660	89.97	21,068,150	1,168,751	55.47
10	3,777,310	181,080	47.94	1,583,030	94,071	59.42	20,619,050	1,072,864	52.03
11	3,577,030	169,350	47.34	1,503,340	89,983	59.86	20,140,670	891,398	44.26
12	3,812,980	155,860	40.88	1,580,120	86,684	54.86	21,204,840	939,010	44.28
1	3,846,740	180,190	46.84	1,663,460	73,816	44.37	21,260,740	1,112,143	52.31
2	3,272,510	188,480	57.59	1,532,950	92,953	60.64	20,366,920	1,192,799	58.57
3	3,874,050	187,361	48.36	1,646,690	109,902	66.74	22,569,680	1,222,268	54.16

(※3) R4年度から高塩基度ポリ塩化アルミニウムを使用